



電力規格

- (1) 圖例: □ 電源插座 (最高負荷為2.6千瓦, 每組3安培)
- (2) 注意事項:

- (a) 所有展品及金屬裝置的電器部份必須小心接地, 或以雙重絕緣體保護。
- (b) 所有展品及裝置的電器部份必須裝有保險絲。
- (c) 每個展覽攤位均須裝置轉掣。
- (d) 如有任何疑問, 必須諮詢大會堂機電工程部。

附註:

- (1) 如需安裝臨時裝置展覽重型物品/設置電器, 必須於擬定展覽日期兩個月前, 透過屯門大會堂經理, 把圖則交予建築署及消防署署長批核, 每份圖則需要五份影印本。
- (2) 樓面載荷: 每平方米100磅(每平方米488千克)
- (3) 樓底高度: 4米
- (4) 牆壁質料: 布牆紙

ELECTRICAL SPECIFICATION

- (1) Key: □ Socket outlets (maximum loading of 2.6 KW, 3 Amp per group)
- (2) Attentions:
 - (a) All exhibits and metallic equipment must be earthed properly or protected with double insulation.
 - (b) All exhibits and equipment must be protected with fuse.
 - (c) Each display counter should be provided with sub-main fused switch.
 - (d) Town Hall Electrical and Mechanical Service Section should be consulted in the event of any enquiry.

Notes:

- (1) If erection of temporary structure/display of heavy exhibits/installation of electrical fittings are required. Plans should be submitted to the Building Authority and Director of Fire Services for approval through Tuen Mun Town Hall Manager two months prior to the proposed exhibition. Five copies of relevant plan(s) are required.
- (2) Floor loading: 100lb per sq ft. (488kg per sq m.)
- (3) Ceiling height: 4m
- (4) Wall material: Sempatap decor wall paper.